



Product Service

# CERTIFICATE

No. Z1A 024192 1877 Rev. 00

**Holder of Certificate:** **ISC GmbH**  
**International Service Center**  
Eschenstraße 6  
94405 Landau/Isar  
GERMANY

**Factories:** 053543

**Certification Mark:**



**Product:** **Generator/Transformer/Accumulator, portable**  
**Gasoline generator set**

**Model(s):** **BT-PG 5500/1**

**Parameters:** Rated voltage: 400VAC, 3P+N+PE/230VAC  
Rated frequency: 50Hz  
Rated output power: 3600W/3000W  
Max. Power: 4800W, S2 5min/ 3300W, S2 5min  
Protection class: I  
Degree of protection : IP23M

**Tested according to:** EN ISO 8528-13:2016  
AfPS GS 2014:01 PAK

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

**Test report no.:** 701291901001-00  
**Valid until:** 2024-01-23

**Date,** 2019-04-30 ( Liwei Sun )

# ZERTIFIKAT

**Nr. Z1A 024192 1877 Rev. 00**

**Zertifikatsinhaber:**

ISC GmbH

## International Service Center

Eschenstraße 6  
94405 Landau/Isar  
DEUTSCHLAND

### Fertigungsstätte:

053543

**Prüfzeichen:**

**Produkt:**

## Stromerzeuger/-wandler/-speicher, tragbare Benzingenerator Set

**Modell(e):**

**BT-PG 5500/1**

### Kenndaten:

Nennausgangsspannung: 400VAC, 3P+N+PE/230VAC;  
Nennfrequenz: 50Hz  
Ausgangsleistung: 3600W/3000W  
Max. Leistung : 4800W, S2 5min/3300W, S2 5min  
Schutzklasse: I  
Schutzart: IP23M

**Geprüft nach:**

EN ISO 8528-13:2016  
AfPS GS 2014:01 PAK

Das Produkt entspricht hinsichtlich der Gewährleistung von Sicherheit und Gesundheit den Anforderungen des deutschen Produktsicherheitsgesetzes § 20 bis 22 ProdSG. Es kann mit den oben abgebildeten Prüfzeichen gekennzeichnet werden. Eine Veränderung der Darstellung der Prüfzeichen ist nicht erlaubt. Die Übertragung eines Zertifikates durch den Zertifikatsinhaber an Dritte ist unzulässig. Das Zertifikat ist gültig bis zum angegebenen Zeitpunkt, sofern es nicht früher gekündigt wird. Umseitige Hinweise sind zu beachten.

Bericht Nr.:

701291901001-00

**Gültig bis:**

2024-01-23

Datum, 2019-04-30

( Liwei Sun )

